

DIRECTORS

JOHN D. KLUGE
PRESIDENT - DIV #1

CHARLES A. HERICH
DIV #2

MICHAEL J. BARRETT
DIV#3

PETE SANCHEZ
DIV #4

DERRICK LUM
VICE PRESIDENT - DIV #5



OFFICERS

CARY KEATEN
GENERAL MANAGER

PAUL R. FUCHSLIN
DISTRICT ENGINEER

MINASIAN, SPRUANCE,
MEITH, SOARES & SEXTON
ATTORNEYS

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este aviso contiene información muy importante sobre su agua potable, por favor lea el aviso en español si va aquí incluido. Si el aviso en español no va incluido aquí, contacte al sistema de agua para pedir una copia.

SID - Pleasant Hill Ranch Estates has levels of Haloacetic Acids Above the Maximum Contaminant Level issued September 15, 2023 FOURTH NOTICE

Our water system continues to fail a drinking water standard. Although this is NOT an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results we have received show that our system exceeds the maximum contaminant level (MCL) of 60 micrograms/liter, for Haloacetic Acids.

What should I do?

- You do not need to use an alternative (e.g., bottled) water supply.
- This is not an immediate risk. If it had been, you would have been notified immediately. However, some people who drink water containing Haloacetic Acids in excess of the MCL over many years may have an increased risk of getting cancer.
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What is being done?

We have increased monitoring frequency, increased flushing in the distribution system, made modifications to storage tank levels, and other system operational processes.

We continue investigating both short and long range options to correct this problem, we will continue providing updates every 3 months.

For more information, please contact; Sue Murphy, Water Quality Coordinator at, 707-455-4021 or by email at smurphy@sidwater.org .